

CQC PRODUCT CERTIFICATION

RFM1-125 / 1P

Summary of verified report parameters

Product	Molded Case Circuit Breaker (MCCB)
Report Number	19101-DWRY220493
CQC Certificate	CQC22107358419
Manufacturer	Suzhou Dongge Power Technology Co., Ltd.
Testing Laboratory	Wenzhou Customs Comprehensive Technical Service Center National Key Laboratory of Low Voltage Electrical Apparatus Testing
Test Standard	GB/T 14048.2-2020
Tested Model Scope	RFM1-125 series including 1P / 2P / 3P / 4P
Rated Current	40A / 50A / 63A / 80A / 100A / 125A
Rated Operational Voltage Ue	AC400V
Rated Insulation Voltage Ui	1000V
Rated Impulse Withstand Voltage Uimp	8kV
Ics	35kA
Icu	55kA
Trip Unit	Thermal-Magnetic
Main Test Categories	Rated parameters; thermal-magnetic trip performance; isolation function; short-circuit breaking performance.
Test Conclusion	Passed according to GB/T 14048.2-2020.