

RFM1-400 SERIES REFERENCE DATA

RFM1-400 Series

Summary of verified report parameters

DOCUMENT SCOPE

The available report covers RFM1-400 3P / 4P configurations only.
It does not establish certification or test coverage for RFM1-400L / 1P.

Product	Molded Case Circuit Breaker (MCCB)
Report Number	19101-DWRY220489
CQC Certificate	CQC22107358650
Manufacturer	Suzhou Dongge Power Technology Co., Ltd.
Testing Laboratory	Wenzhou Customs Comprehensive Technical Service Center National Key Laboratory of Low Voltage Electrical Apparatus Testing
Test Standard	GB/T 14048.2-2020
Tested Model Scope	RFM1-400 / 3300 and RFM1-400 / 4300 - 3P / 4P configurations
Rated Current	250A / 315A / 350A / 400A
Rated Operational Voltage Ue	AC400V
Rated Insulation Voltage Ui	1000V
Rated Impulse Withstand Voltage Uimp	8kV
Ics	50kA
Icu	65kA
Trip Unit	Thermal-Magnetic
Main Test Categories	Rated parameters; thermal-magnetic trip performance; isolation function; short-circuit breaking performance.
Test Conclusion	Passed according to GB/T 14048.2-2020.